

कार्यालय, सहायक अभियंता,
लोक स्वास्थ्य यांत्रिकी उपखण्ड-रायपुर (छ.ग.)

क्रमांक 118 प्र./स.अ./लो.स्वा.या./ उपखण्ड

रायपुर, दिनांक 1.4.2026


प्रति,

Principal
St. Vincent Pallotti School
Jeevodaya vill. Gatapar ,
Tehsil Abhanpur , Dist. Raipur (C.G)

विषय :- Regarding Safe Drinking Water and Sanitary Certificate.
संदर्भ :- आपका पत्र क्र. 17 - Date 23.03.2026

विषयान्तर्गत लेख है कि आपके संदर्भित पत्र के तहत आपके विद्यालय
का Safe Drinking Water & Sanitary Survey सर्टिफिकेट आवश्यक कार्यवाही हेतु आपकी
ओर प्रेषित हैं।

संलग्न :- उपरोक्तानुसार


सहायक अभियंता
लोक स्वास्थ्य यांत्रिकी उपखण्ड,
रायपुर (छ.ग.)

Annexure C


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No:-DL/RPR/42-0A

Dated:- 01.04.2026

It is certified that an inspection team headed by Shri Umesh Sahu, Chief Chemist (Name of Officers with designation) from **State Laboratory & Research Centre Public Health Engineering Department Raipur (C.G.)** (Name of Department /Office) inspected **St. Vincent Pallotti School Jeevodaya vill. Gatapar , Tehsil Abhanpur , Dist. Raipur (C.G)** (Name & Address of the school) on **23.03.2026** (Date of inspection) and on the basis of Water Test Report (Attached) bearing no **56** Dated **25.03.2026** of **State Laboratory & Research Centre Public Health Engineering Department Raipur (C.G.)** (PHED Lab) certified that **St. Vincent Pallotti School Jeevodaya vill. Gatapar , Tehsil Abhanpur , Dist. Raipur (C.G)** (Name of School) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of -: **1 Year (01.04.2026 To 31.03.2027)**


Assistant Engineer,
P.H. Engg. Sub-Division
RAIPUR (C.G.)

Signature with Seal :

Name :- Smt. Rukmini Singh

Designation : Assistant Engineer

Name & Address of the Office / Department :

Public Health Engineering Sub Division- Raipur (C.G.)

To,

Principal

St. Vincent Pallotti School

Jeevodaya vill. Gatapar ,

Tehsil Abhanpur , Dist. Raipur (C.G)

(Name & Address of the institution)

Note:- The Certificate is to be issued by authorized Officer /PHED Lab/Local Bodies.

राज्य प्रयोगशाला एवं अनुसंधान केन्द्र
लोक स्वास्थ्य यांत्रिकी विभाग रायपुर (छ.ग.)
(ई-मेल:- slrcraipur@gmail.com)

क्रमांक111.../राज्य प्रयोगशाला/लो.स्वा.या.वि./2026

रायपुर, दिनांक 25/03/2026

प्रति,


Principal
St. Vincent Pallotti School Jeevodaya
Abhanpur, Raipur (C.G.)

विषय :- जल गुणवत्ता परीक्षण रिपोर्ट & Annexure C प्रेषित करने विषयक।
संदर्भ :- आपका पत्र क्र. 17/दिनांक 23.03.2026

000

उपरोक्त विषयान्तर्गत लेख है कि आपके संदर्भित पत्र के माध्यम से प्राप्त जल नमूना का परीक्षण उपरांत रिपोर्ट आपकी ओर प्रेषित हैं।

संलग्न :-उपरोक्तानुसार


मुख्य रसायनज्ञ
राज्य प्रयोगशाला एवं अनुसंधान केन्द्र,
लोक स्वास्थ्य यांत्रिकी विभाग
रायपुर (छ.ग.)

राज्य प्रयोगशाला एवं अनुसंधान केन्द्र
लोक स्वास्थ्य यांत्रिकी विभाग रिंगरोड 1, रावणभाटा, रायपुर (छ.ग.)
STATE LABORATORY & RESEARCH CENTRE, PHED,
RING ROAD NO.1 RAWANBHANTA RAIPUR (C.G.)
email:- slrcraipur@gmail.com

Test Report (Drinking Water) No.-56

Senders name & address:- Principal St. Vincent Pallotti School Jeevodaya Abhanpur, Raipur (C.G.)	Discipline:- Chemical Testing	Group:- Drinking Water	Test performed at Laboratory:- Permanent facility	
	Senders letter no./Date	17/23-03-2026	Sampled by	Customer
	SL Receipt no.	03/26/56	Physical condition of Sample	Ok
	SL Receipt date	23-03-2026	Date of analysis started	23-03-2026
			Date of analysis completed	25-03-2026

Sample Details

S.N.	Sample I.D.	District /Block	City / Village	Source	Location/Source ID./GPS Identification
01	03/26/56/414	Raipur	Gatapar	-	St. Vincent Pallotti School Jeevodaya Abhanpur, Raipur (C.G.)
-	-	-	-	-	-
-	-	-	-	-	-
-	-	-	-	-	-
-	-	-	-	-	-

Details of parameters their test method units and specification as per IS/APHA

S.N.	Characteristics	Test method IS:3025/APHA 24 th edition		Unit of Measure ment	As per BIS-10500:2012 For Drinking water		Result				
		method	Part no.		Sample ID →		414	-	-	-	-
					Acceptable limit	Permissible limit					
1	Colour	APHA	Part 2120-B	Hazen	5	15	6	-	-	-	-
2	Turbidity	APHA	2130-B	NTU	1	5	0.08	-	-	-	-
3	pH @ 25 th c	APHA	Part 4500-H-B	-	6.5-8.5	No Relaxation	7.69	-	-	-	-
4	Conductivity	APHA	2510-B	µS/cm.	-	-	402	-	-	-	-
5	Fluoride as F ⁻	APHA	Part 4500-F-C	Mg/l.	1.0	1.5	0.256	-	-	-	-
6	Total Hardness as CaCO ₃	APHA	Part 2340-C	Mg/l.	200	600	239.77	-	-	-	-
7	Calcium as Ca	APHA	Part 3500-Ca-B	Mg/l.	75	200	60.26	-	-	-	-
8	Magnesium as Mg	APHA	3500-Mg-B	Mg/l.	30	100	21.72	-	-	-	-
9	Chloride as Cl ⁻	APHA	Part 4500-Cl-B	Mg/l.	250	1000	20.94	-	-	-	-
10	Alkalinity as CaCO3	APHA	Part 2320-B	Mg/l.	200	600	173.91	-	-	-	-
11	TDS	APHA	Part-2540-C	Mg/l	500	2000	266	-	-	-	-
12	Iron as Fe	APHA	Part3500-Fe-B	Mg/l	1.0	No Relaxation	0.10	-	-	-	-
13	Nitrate as NO ₃	APHA	Part 4500 -NO3-B	Mg/l.	45	No Relaxation	12.8	-	-	-	-
14	Sulphate as SO ₄	APHA	Part 4500-SO4-E	Mg/l	200	400	7.35	-	-	-	-
15	Odour	IS:3025	Part -5	-	Agr.	Agr.	Agr.	-	-	-	-
16	Residual Chlorine	IS-3025	Part-26	Mg/l.	0.2	1.0	0.0	-	-	-	-

1. The report should not be produced partly or full without approval signatory authority of legal purpose.
2. The results refer only to tested samples and parameters.
3. Samples will be retained for a period of 7 days from date of issue of test report.
4. This Lab does not hold any responsibility for variation in results of samples kept on hold for wants of clarification.
5. Results apply to the sample as received.
6. Sampling not done by Lab staff.
7. Agreeable is denoted by Agr.

Report reviewed & Approved by


(Umesh Sahu)
Chief Chemist

Issue no. 56/Date- 25-03-2026

Page no. 01/01

.....End of Report.....

राज्य प्रयोगशाला एवं अनुसंधान केन्द्र
लोक स्वास्थ्य यात्रिकी विभाग रिंगरोड 1, रावणभाठा, रायपुर (छ.ग.)
STATE LABORATORY & RESEARCH CENTRE, PHED.
RING ROAD NO.1 RAWANBHANTA RAIPUR (C.G.)
email:- slrcraipur@gmail.com

Bacteriological - Test Report (Drinking Water) No. 56

Senders name & address:- Principal St. Vincent Pallotti School Jeevodaya Abhanpur Raipur (C.G.)	Discipline:- Chemical Testing	Group:- Drinking Water	Test performed at Laboratory:- Permanent facility	
	Senders letter no./Date	17/23/03/2026	Sampled by	Customer
	SL receipt no.	03/26/56	Physical condition of Sample	Ok
	SL Receipt date	23-03-2026	Date of analysis started	23-03-2026
			Date of analysis completed	25-03-2026

Sample Details


S.N.	Sample I.D.	District /Block	City / Village	Source	Location/Source ID./GPS Identification
01	03/26/56/414	Raipur	Gatapar	-	St. Vincent Pallotti School Jeevodaya Abhanpur, Raipur (C.G.)
-	-	-	-	-	-
-	-	-	-	-	-
-	-	-	-	-	-
-	-	-	-	-	-

Details of parameters their test method units and specification as per IS/APHA

S.N.	Parameters	Test method		As per IS-10500-2012 drinking water		Result				
		Method	Unit	Sample ID →		414	-	-	-	-
				Acceptable limit	Permissible limit					
01	E. Coli	APHA / IS	Cfu/100ml.	Nil	Nil	Nil	-	-	-	-

1. It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicated under the "permissible" limit in the absence of alternate source in column 7 above which the sources will have to be rejected.
2. The results refer only to tested samples and parameters.
3. Samples will be stored for a period of 7 days from date of issue of report.
4. This Lab does not hold any responsibility for variation in results of samples kept on hold for wants of clarification.
5. Results apply to the sample as received.
6. Sampling not done by Lab staff.

Report reviewed & Approved by


(Umesh Sahu)
Chief Chemist

Issue no. 56/ Date- 25-03-2026

Page no. 01/01

.....End of Report.....

राज्य प्रयोगशाला एवं अनुसंधान केन्द्र
लोक स्वास्थ्य यांत्रिकी विभाग रिंगरोड 1, रावणभाठा, रायपुर (छ.ग.)
STATE LABORATORY & RESEARCH CENTRE, PHED.
RING ROAD NO.1 RAWANBHANTA RAIPUR (C.G.)
email:- slrcraipur@gmail.com

Invoice (Water Sample Analysis Charge)

Invoice no. 30

Date 25.03.2026


To,

Principal
St. Vincent Pallotti School Jeevodaya
Abhanpur, Raipur (C.G.)

Description

Sr. no.	Parameters	Fee in Rs. Per sample	Required parameter tick (✓)	Total fee in Rs. according to no. of sample = 01
1	Turbidity in NTU	5.00	✓	5.00
2	pH	1.00	✓	1.00
3	Total Alkalinity as CaCO ₃ in Mg/l.	20.00	✓	20.00
4	TDS in Mg/l.	1.00	✓	1.00
5	Chloride in Mg/l.	50.00	✓	50.00
6	Total Hardness as CaCO ₃ in Mg/l.	20.00	✓	20.00
7	Calcium Mg/l.	20.00	✓	20.00
8	Magnesium Mg/l.	20.00	✓	20.00
9	Fluoride in Mg/l.	50.00	✓	50.00
10	Iron in Mg/l.	50.00	✓	50.00
11	Nitrate in Mg/l.	50.00	✓	50.00
12	Sulphate Mg/l.	50.00	✓	50.00
13	Odour	1.00	✓	1.00
14	Residual Chlorine	1.00	✓	1.00
15	Conductivity in mg/l.	1.00	✓	1.00
16	Colour	1.00	✓	1.00
17	E. Coli	100.00	✓	100.00
Grand Total				441.00

[**Invoice** Amount In words ₹. Four Hundred Forty One Rupees only]



Chief Chemist
State Laboratory & Research Centre
PHE Deptt. RAIPUR (C.G.)

[Pls Pay Testing Charge by DD/ cheque in a favour of:- Executive Engineer Public Health Engineering Division Raipur (C.G.)]